



Solex Architecture, Inc.  
641 Main Street  
Danville, Virginia 24541  
434.688.0767  
[www.solexarchitecture.com](http://www.solexarchitecture.com)

**February 26, 2026**  
**Clarksville Volunteer Fire Department**  
**Addendum 2**

**General**

- 1) Direct all calls to schedule site visits to one of the following contacts:
  - a. Matt Carter: (434)774-7251
  - b. Tommy Franco: (434)210-1513

**Architectural**

- 1) The restroom renovation is classified as Alteration – Level 1 (VEBC section 601.2.1), as the work only includes removing and replacing existing materials, elements, fixtures, and equipment. Per VEBC section 602, this level of alteration does not require the room to be brought up to meet current code or accessibility requirements.